

**SAINT PETERSBURG STATE UNITARY ENTERPRISE
“PETERSBURG’S SUBWAY”**

October 16, 2002

ACT

No. 1

Saint Petersburg

*Re. Tests of Impulse Fire Extinguishers
“Impulse Storm” on Objects of Petersburg’s Subway*

We, the undersigned, Deputy Chief of Department of Departmental Fire Prevention Service of Petersburg’s subway A.N.Mashevsky, General Director of Scientific and Production Company “New Impulse Technologies” (Kiev) V.A.Ivanov, General Director of Closed Joint-Stock Company “Specialized enterprise of fire prevention works”(Moscow) V.N.Yevstigneev, have drawn up the present Act that on October 16, 2002 in a subway tunnel and on undercar subway equipment in the electric depot “Avtovo” conducted fire tests of fire extinguishers “Impulse Storm”(hereinafter referred to as “the Fire extinguisher”) and determined the following in the result:

1. The Fire extinguisher allows to liquidate a fire center in a tunnel in the area of electric cables laid on tubings at the height of 3 and 5 meters.
2. The Fire extinguisher allows to liquidate a fire center in boxes of undercar subway equipment.
3. Taking into account the performed attestation of the Fire extinguisher on extinguishing fire centers without withdrawing voltage up to 35,000 volts, it is recommended for introduction on subway objects.

<Seal>

<signature> A.N.Mashevsky
<signature> V.A.Ivanov
<signature> V.N.Yevstigneev